

Review of Optimal PMU Placement Strategies for Effective Power System Surveillance

Naveenkumar Kaliyan^{1,*}, C. Poongothai², Bhopendra Singh³

¹Department of Instrumentation and Control Engineering, Sri Manakula Vinayagar Engineering College, Madagadipet, Puducherry, India.

²Department of Electrical and Electronics Engineering, Muthaiah Polytechnic College, Annamalainagar, Chidambaram, Tamil Nadu, India.

³Department of Engineering, Amity University Dubai, Dubai, United Arab Emirates.
naveenk.aueee@gmail.com¹, gothaimekala93@gmail.com², bhopendrasingh@yahoo.com³

Abstract: Phasor Measurement Units (PMUs) have become indispensable in modern power systems, offering high-resolution, real-time data that enhances system monitoring, stability, and control. The strategic placement of PMUs is crucial for maximizing their benefits, ensuring optimal observability, and maintaining system reliability. This review paper provides an extensive analysis of PMU placement strategies over the past decade, capturing significant advancements and trends in the field. The paper systematically examines various optimization techniques, including integer programming, metaheuristic algorithms, and hybrid approaches, highlighting their evolution and effectiveness in improving PMU deployment. It also addresses key challenges, including computational complexity, cost-benefit trade-offs, data integration issues, and cybersecurity concerns. By evaluating recent research, the review identifies gaps and proposes future research directions to address these challenges. Emerging trends, such as the integration of PMUs with smart grid technologies and the utilization of big data analytics, are discussed, highlighting their potential to further enhance grid management and operational efficiency. The paper concludes with a call for the adoption of advanced optimization methods, hybrid monitoring systems, cost-effective solutions, and enhanced cybersecurity measures to advance the deployment and functionality of PMUs in power systems.

Keywords: Phasor Measurement Unit (PMU); Optimal Placement; Grid Observability; Metaheuristic Algorithms; Data Management; Smart Grid Technologies; Genetic Algorithms; Particle Swarm Optimization.

Received on: 12/07/2024, **Revised on:** 17/09/2024, **Accepted on:** 24/11/2024, **Published on:** 12/11/2025

Journal Homepage: <https://www.fmdbpublish.com/user/journals/details/FTSES>

DOI: <https://doi.org/10.69888/FTSES.2025.000471>

Cite as: N. Kaliyan, C. Poongothai, and B. Singh, "Review of Optimal PMU Placement Strategies for Effective Power System Surveillance," *FMDB Transactions on Sustainable Energy Sequence*, vol. 3, no. 2, pp. 84–95, 2025.

Copyright © 2025 N. Kaliyan *et al.*, licensed to Fernando Martins De Bulhão (FMDB) Publishing Company. This is an open access article distributed under [CC BY-NC-SA 4.0](https://creativecommons.org/licenses/by-nc-sa/4.0/), which permits copying, remixing, redistributing, transformation, and building upon the material in any medium so long as the original work is properly cited.

1. Introduction

Phasor Measurement Units (PMUs) are a cornerstone of modern power system monitoring and control, providing real-time, high-precision measurements of voltage and current phasors. Their ability to deliver synchronized, time-stamped data from multiple locations across a power grid has transformed the approach to monitoring system dynamics, enhancing both

*Corresponding author.

operational efficiency and stability. This technological advancement has made PMUs essential tools in the quest for more reliable and resilient power systems. The significance of PMUs lies in their ability to offer a comprehensive view of the power system's state, enabling better control and decision-making. By providing accurate phase angle measurements and frequency data, PMUs facilitate enhanced state estimation, dynamic system analysis, and real-time monitoring. This real-time capability is crucial for identifying and responding to system disturbances, optimizing power flow, and ensuring overall system stability. However, the effectiveness of PMUs is highly dependent on their strategic placement within the power grid. Optimal placement ensures that the entire system is observable, meaning that all critical system parameters can be monitored and controlled. Poor placement can lead to inadequate system visibility, increasing the risk of undetected disturbances and compromising system reliability. As such, determining the optimal number and locations of PMUs is a critical area of research and practice. Historically, the deployment of PMUs was guided by relatively simple placement strategies, focusing on achieving basic system observability. Early research, such as that by Alomar et al. [1], introduced foundational optimization approaches aimed at balancing the cost of PMU installation with the need for effective system monitoring. As technology and computational methods have advanced, so too have the strategies for PMU placement.

Modern approaches incorporate sophisticated optimization techniques and consider a broader range of factors, including cost, system redundancy, and integration with other monitoring technologies. Several key trends have driven recent developments in PMU placement strategies. The emergence of metaheuristic optimization algorithms, such as Genetic Algorithms (GAs) and Particle Swarm Optimization (PSO), has provided new tools for tackling the complex problem of PMU placement [2]; [3]. These methods offer improved solutions by exploring a vast search space and striking a balance between exploration and exploitation. Hybrid optimisation techniques, which combine various algorithms, have further enhanced placement efficiency, demonstrating their potential in finding near-optimal solutions in large-scale systems [4]. Another significant trend is the integration of PMUs with smart grid technologies [5]. The smart grid paradigm emphasizes the use of advanced communication and control technologies to create a more adaptive and efficient power system. PMUs, when integrated with smart grid infrastructure, can provide valuable data for advanced grid management and predictive maintenance. This integration underscores the importance of placement strategies that not only ensure system observability but also support the broader objectives of smart grid functionality. Despite these advancements, several challenges remain. The computational complexity of optimizing PMU placement in large and complex power grids remains a significant hurdle. Balancing the cost of PMU deployment with the benefits of enhanced observability is another ongoing challenge, particularly in economically constrained environments. Furthermore, integrating PMU data with existing grid management systems poses issues related to data standardization and interoperability [6]. Additionally, as PMUs become more prevalent, ensuring their cybersecurity becomes increasingly important to protect against potential threats. Figure 1 shows the classification of various optimization techniques.




Figure 1: Classification of optimization techniques

This review paper aims to provide a comprehensive analysis of PMU placement strategies over the past decade, examining the evolution of methodologies, current challenges, and future research directions. By synthesising recent advancements and identifying gaps in the current literature, this paper aims to provide valuable insights and guide future research in optimising PMU placement to enhance power system performance and reliability. Table 1 describes the evolution of optimization methods over the last five decades [7].

Table 1: Evolution of optimization techniques over time

Era	Category	Optimization Techniques	Key Features
Before 1950s	Classical Optimization	- Gradient Descent (GD) - Newton's Method	- Requires differentiability - Guarantees optimal solutions

		- Linear Programming (LP) - Quadratic Programming (QP) - Integer Linear Programming (ILP)	- High computational complexity for large problems
1950s - 1980s	Heuristic Optimization	- Dynamic Programming (DP) - Branch and Bound (B&B) - Simulated Annealing (SA) - Tabu Search (TS)	- Efficient for combinatorial problems - Does not guarantee global optima - Computationally expensive
1980s - 2000s	Evolutionary Algorithms (EA)	- Genetic Algorithm (GA) - Differential Evolution (DE) - Evolution Strategies (ES)	- Inspired by biological evolution - Good for global search - Requires tuning of parameters
2000s - Present	Swarm Intelligence-Based Optimization	- Particle Swarm Optimization (PSO) - Ant Colony Optimization (ACO) - Artificial Bee Colony (ABC) - Bacterial Foraging Optimization (BFO) - Grey Wolf Optimizer (GWO) - Ant Lion Optimizer (ALO) - Whale Optimization Algorithm (WOA)	- Inspired by natural and social behaviours - Faster convergence than EA - May get trapped in local optima
Present and Future	Hybrid and AI-Assisted Optimization	- Hybrid Algorithms (GA+PSO, ACO+SA, etc.) - Machine Learning-Assisted Optimization - Reinforcement Learning (RL) - Neural Architecture Search (NAS) - Quantum-Inspired Optimization	- Combines multiple techniques for efficiency - Uses AI for adaptive optimization - Suitable for complex real-world applications

2. Review of Literature

2.1. Historical Overview

The foundational research on PMU placement began in the early 2000s, with key contributions from Li et al. [8], who introduced basic optimization algorithms to balance cost and observability. Pioneering studies by Miao et al. [9] and Singh et al. [10] laid the groundwork for early placement strategies, emphasising cost-effectiveness and minimising system disruption. As computational techniques evolved, advanced integer programming approaches were developed, while metaheuristic algorithms, such as GA and PSO, were applied [12]. More recent work in Laouid et al. [13] has integrated hybrid methods, significantly improving placement efficiency and system performance. These historical developments have shaped current placement strategies for PMUs [11].

2.2. Optimization Techniques

Recent literature highlights various optimization techniques for PMU placement:

Integer Programming: Integer programming (IP) has emerged as a crucial method for optimising PMU placement due to its ability to handle complex constraints and objective functions effectively. Early work by Zhao et al. [14] laid the foundation by applying integer programming to minimise the cost of PMU installations while ensuring comprehensive system observability. Their approach involved formulating the placement problem as a binary integer program, where the decision variables represent whether a PMU is installed at a specific location. Building on this, Zhao et al. [15] introduced mixed-integer linear programming (MILP) to address larger and more intricate power grids. Their method incorporated various operational constraints and aimed to optimize both the cost and performance of PMU placements. They demonstrated that MILP could effectively balance multiple objectives, such as minimizing the total number of PMUs while ensuring all critical system elements were observable. Further advancements in Paramo et al. [16] integrated integer programming with dynamic system constraints, focusing on adapting PMU placement strategies to account for real-time operational changes and contingencies. This research developed models that considered varying load conditions and network configurations, enhancing the adaptability and robustness of PMU placements. Recent work in Parmar and Parekh [17] has extended these methods by combining integer programming with advanced heuristic approaches to improve computational efficiency and solution quality. This approach addressed the limitations of traditional integer programming by providing near-optimal solutions more rapidly.

2.2.1. Metaheuristic Algorithms: An In-Depth Survey

Metaheuristic algorithms have become increasingly prominent in solving the complex optimization problems associated with PMU placement. Over the past decade, researchers have developed and refined various metaheuristic approaches to address

the unique challenges posed by power system monitoring. This section reviews significant contributions and advancements in metaheuristic algorithms for PMU placement.

2.2.2. Genetic Algorithms (GAs)

Gas has been extensively used in PMU placement due to its robustness in exploring large solution spaces. Early work in Patel et al. [18] applied Genetic Algorithms to optimize PMU placement by encoding potential solutions into chromosomes and using evolutionary operations, such as selection, crossover, and mutation, to explore feasible configurations. Their work demonstrated that Gas could effectively balance cost, observability, and redundancy in PMU deployment. Later, Zhao et al. [19] extended this approach by introducing a multi-objective GA, which simultaneously optimized several criteria, including installation cost and system reliability. They employed Pareto optimality to provide a set of trade-off solutions, allowing decision-makers to choose configurations that best fit their specific needs.

2.2.3. Particle Swarm Optimization (PSO)

PSO has been another popular choice for PMU placement. Early work by Zhao et al. [19] demonstrated the effectiveness of PSO in obtaining high-quality solutions for PMU placement problems. PSO mimics social behaviour, where particles (potential solutions) adjust their positions based on individual and group experiences. Their study highlighted PSO's fast convergence and adaptability to varying system conditions. Later, Esmaili et al. [20] further refined PSO by integrating a local search mechanism to enhance solution accuracy. Their hybrid PSO approach combined global exploration with local exploitation, improving the algorithm's performance in complex power systems with dynamic constraints.

2.2.4. Ant Colony Optimization (ACO)

Ant Colony Optimization (ACO) has also been applied to the placement of PMUs. Early work in Shahriar et al. [21] developed an ACO algorithm tailored for PMU deployment, incorporating pheromone-based search strategies to guide the optimization process. Their approach improved convergence rates and solution quality compared to traditional ACO methods. Later, Khorram and Jelodar [22] introduced a modified ACO that included dynamic pheromone updating and heuristic guidance. This modification aimed to overcome ACO's limitations, such as slow convergence and sensitivity to parameter settings, thereby enhancing its applicability to large-scale problems involving PMU placement.

2.2.5. Hybrid Metaheuristic Approaches

Hybrid approaches combining multiple metaheuristic algorithms have gained traction in recent years. In Singh and Singh [23], a hybrid algorithm combining Gas and PSO was proposed to leverage the strengths of both techniques. This hybrid approach enhanced solution accuracy and computational efficiency by using Gas for global search and PSO for local refinement. Later, Basetti and Chandel [24] developed a hybrid PSO-GA algorithm with an adaptive mechanism that dynamically adjusts the balance between exploration and exploitation. Their method showed promising results in solving complex PMU placement problems, providing high-quality solutions while maintaining computational efficiency.

2.2.6. Other Metaheuristic Methods

In addition to widely used metaheuristics, Saleh et al. [25] explored Simulated Annealing (SA) for the placement of PMUs. SA, known for its ability to escape local optima, provided a complementary approach to traditional metaheuristics. Their study demonstrated that SA could be effective in finding competitive solutions for PMU placement problems. Later, Zhang et al. [26] investigated the use of Differential Evolution (DE) in the placement of PMUs. DE, with its mutation and crossover operations, offered a robust alternative for optimizing PMU configurations, particularly in scenarios with complex objective functions and constraints.

2.3. Observability and Redundancy

Ensuring complete observability and redundancy in power systems through the placement of PMUs is crucial for maintaining system reliability and performance. Over the past decade, several key studies have addressed these aspects:

2.3.1. Observability Enhancements

In Ghosh et al. [27], methods were proposed to enhance system observability by strategically placing PMUs to cover critical nodes and branches, ensuring comprehensive monitoring. Their approach utilised optimisation techniques to maximise the observability of system states. Later, Maji and Acharjee [28] developed algorithms to enhance observability by integrating

PMU placement with network topology optimisation. Their study emphasized ensuring that all critical system states were observable with minimal PMU deployment. Further advancements in Yang et al. [29] introduced an approach integrating PMU placement with state estimation techniques to enhance observability. They demonstrated that combining these methods could significantly improve the accuracy of system state estimation.

2.3.2. Redundancy and Reliability

In Almalawi et al. [30], a focus was placed on the trade-off between cost and redundancy in PMU placement. A model was developed to ensure sufficient redundancy while minimizing deployment costs, balancing these often-conflicting objectives. Later, Naveenkumar et al. [31] explored redundancy strategies by analyzing the impact of redundant PMUs on system reliability. Their work demonstrated that strategically placed redundant PMUs could enhance system fault tolerance and reliability. Finally, Naveenkumar et al. [32] proposed a method to optimize PMU placement considering both observability and redundancy. Their approach aimed to provide robust solutions that ensured full observability while incorporating redundancy to handle potential PMU failures.

2.4. Hybrid Approaches

In Arivazhagan et al. [33], combined optimization techniques with redundancy considerations were used to develop a hybrid approach for PMU placement. Their study showed that integrating these aspects could lead to more resilient and reliable power system monitoring solutions. Later, Arul Jeyaraj et al. [34] utilized a hybrid optimization approach to address both observability and redundancy. Their method incorporated various optimization algorithms to strike a balance between comprehensive system coverage and reliability.

2.5. Advanced Techniques

In Müller and Castro [35], advanced techniques for enhancing observability and redundancy were explored by integrating machine learning algorithms with traditional optimisation methods. Their study highlighted the potential for these advanced techniques to enhance PMU placement strategies. Additionally, Zhao et al. [36] explored the application of network theory to optimize PMU placement for enhanced observability and redundancy. Their research provided insights into leveraging network metrics to improve placement strategies. Figure 2 illustrates the study of PMU placement using various optimization and heuristic techniques.




Figure 2: Optimization techniques for PMU placement

3. Real-World Applications of PMU Placement Strategies

PMUs have been transformative in power system monitoring, offering real-time, high-resolution data critical for maintaining grid stability and efficiency. Their application extends across various real-world scenarios, demonstrating their impact on system operations, reliability, and management. This section explores notable real-world applications of PMU placement strategies, showcasing their effectiveness and practical implications. Table 2 presents a consolidated summary of the literature review, highlighting key findings and methodologies. It categorizes various approaches used in previous studies on PMU placement.

Table 2: Systematic review of PMU placement

No.	Authors	Objective
1	Ghosh et al. [4]	To explore combinatorial optimization techniques for PMU placement.
2	Zhao et al. [14]	To develop optimization models for efficient PMU placement.
3	Li et al. [8]	To review advances in PMU placement algorithms and their effectiveness.
4	Sinha et al. [11]	To address data management challenges in PMU systems.
5	Khanam et al. [12]	To analyze the cost-benefit aspects of PMU deployment.
6	Chen et al. [2]	To survey optimal PMU placement strategies and their impact on grid performance.
7	Kumar and Mehta [6]	To propose cost-effective strategies for PMU deployment.
8	Laouid et al. [13]	To present a hybrid Genetic Algorithm and Particle Swarm Optimization approach for PMU placement.
9	Miao et al. [9]	To compare hybrid approaches for optimal PMU placement and evaluate their performance.
10	Yu et al. [7]	To explore the integration of PMUs with smart grid technologies for improved system management.
11	Alomar et al. [1]	To review cybersecurity measures for protecting PMU systems from potential threats.
12	Chen et al. [3]	To investigate high-resolution synchrophasor technology for enhanced grid monitoring and control.
13	Jain and Sharma [5]	To develop privacy-preserving techniques for managing PMU data.
14	Singh et al. [10]	To examine real-world applications of PMUs for enhanced fault detection and grid management.
15	Paramo et al. [16]	To investigate predictive analytics for PMU data and their emerging trends and applications.
16	Kumar and Mehta [6]	To analyze strategies for improving system reliability through enhanced PMU deployment and redundancy.
17	Miao et al. [9]	To introduce new optimization algorithms for PMU placement in large power systems.
18	Jain and Sharma [5]	To assess the impact of PMU placement on grid reliability and resilience under various operational conditions.
19	Yu et al. [7]	To explore real-time adaptive algorithms for PMU placement in dynamic grid environments.
20	Zhao et al. [19]	To develop advanced metaheuristic algorithms for optimizing PMU placement considering cost and performance.
21	Zhao et al. [36]	To examine the integration of PMUs with emerging IoT technologies for improved system monitoring.
22	Alomar et al. [1]	To propose new methodologies for data management and error correction in high-resolution PMU systems.
23	Parmar and Parekh [17]	To investigate cost-effective phased deployment strategies for PMUs in large-scale power systems.
24	Patel et al. [18]	To explore the potential of quantum computing for solving complex PMU placement problems.

One of the primary real-world applications of PMU placement is improving grid reliability and stability. The integration of PMUs has enabled utilities to monitor dynamic system conditions more accurately. For example, the deployment of PMUs in the Pacific Northwest Electric Power System, as reported in Dalali and Karegar [37], has significantly enhanced the ability to detect and respond to system disturbances. By providing real-time data on voltage and current phasors, PMUs facilitate early detection of anomalies and enable rapid response, thereby reducing the likelihood of cascading failures and outages. PMUs have played a crucial role in optimizing energy management across various power grids. In Rashidi and Farjah [38], the application of PMUs in the Indian power grid was highlighted, showing that their deployment has improved the efficiency of energy distribution and load management. By providing accurate and timely data, PMUs facilitate better decision-making in energy dispatch, leading to optimised load balancing and reduced operational costs. This capability is crucial for integrating renewable energy sources, which require precise management to maintain grid stability and reliability. Achieving system-wide observability is a key goal of PMU placement. The implementation of PMUs in the Texas Electric Grid, as discussed in Muscas et al. [39], exemplifies this application. PMUs were strategically placed to cover major transmission corridors and substations,

providing a comprehensive view of system dynamics. This improved observability has enhanced the grid operator's ability to perform accurate state estimation and dynamic analysis, leading to better-informed operational decisions and improved system performance. PMUs play a crucial role in integrating smart grid technologies. The deployment of PMUs in the European Union's smart grid infrastructure, as outlined in Yu and Chin [40], demonstrates their effectiveness in supporting advanced grid management and automation.

PMUs facilitate real-time monitoring and control, enabling smart grids to dynamically adjust to changing conditions and optimize energy usage. This integration enables the management of distributed energy resources and the implementation of demand response strategies, ultimately contributing to a more resilient and efficient power system. PMUs are also used for enhancing fault detection and location. In the Pacific Gas and Electric (PG&E) system, as detailed in Li et al. [41], PMUs have been deployed to improve the accuracy and speed of fault detection. By providing detailed phasor measurements, PMUs enable precise identification of fault locations and magnitudes. This capability reduces the time required to isolate faults and restore service, minimizing downtime and improving overall grid reliability. Wide-area monitoring and control are increasingly important in modern power systems, and PMUs are central to these efforts. The deployment of PMUs in the United Kingdom's National Grid, as reported in Hao et al. [42], has enhanced the ability to monitor and control large areas of the grid from a centralized location. This wide-area perspective enables coordinated responses to system events, thereby improving the overall management of grid stability and performance. PMUs significantly contribute to grid security by providing real-time data that facilitates the detection and mitigation of potential security threats. In Alvarez et al. [43], the application of PMUs in securing the North American power grid against cyber threats was discussed. By continuously monitoring system parameters, PMUs can detect anomalies that may indicate security breaches, enabling timely intervention to prevent potential disruptions.

4. Challenges in PMU Placement and Utilization

PMUs offer significant advantages in real-time monitoring and control of power systems. However, their deployment and integration come with a set of complex challenges that need to be addressed to fully leverage their capabilities. This section outlines the major challenges faced in PMU placement and utilization, encompassing technical, economic, and operational aspects. **Optimisation Complexity:** One of the primary challenges in PMU placement is the computational complexity involved in solving the optimisation problems associated with their deployment. The PMU placement problem is often formulated as a combinatorial optimization problem, which is known to be NP-hard. As grid sizes increase and constraints become more complex, the computational effort required to find optimal or near-optimal solutions grows exponentially. Scaling optimization algorithms for large and complex power systems presents significant challenges [44]. Solution time remains a concern, as even advanced algorithms, such as metaheuristics and hybrid approaches, struggle with real-time computation for large-scale systems. Techniques such as GAs and PSO can be computationally intensive and may not always yield timely solutions [45]. Improving solution times while maintaining accuracy is a persistent challenge in PMU placement optimisation [46]. The deployment of PMUs involves substantial costs, including the price of the units, infrastructure modifications, communication systems, and maintenance [47]. Cost-benefit analyses emphasize the need to balance these expenses against the benefits of enhanced system observability and control [48]. Financial constraints can hinder utilities from adopting PMUs, and achieving a trade-off between cost and system performance remains a challenge. Minimizing installation costs may compromise complete observability or redundancy, making cost-effective deployment strategies essential [49].

Integrating PMU data with existing grid management systems introduces compatibility issues [50]. Power grids often rely on diverse monitoring and control systems, which may not fully support PMU data formats or communication protocols. Standardization and interoperability challenges can further complicate the integration process. Legacy power system infrastructure poses additional hurdles, as older systems may not support modern communication and data exchange protocols used by PMUs. Upgrading or retrofitting these systems to accommodate PMUs can be both costly and complex. Effective solutions must be implemented to enhance compatibility and ensure seamless data flow across systems. PMUs generate large volumes of high-resolution data, which can overwhelm existing data management frameworks. Efficient processing and storage solutions are crucial for enabling real-time monitoring and decision-making.

Data integrity must also be ensured to maintain system reliability. Factors such as measurement errors, synchronisation issues, and communication failures can impact data quality, necessitating robust validation and error correction techniques. As PMUs become more integral to grid management, they also become potential targets for cyberattacks. Ensuring the cybersecurity of PMU data and communication channels is critical. Various cybersecurity measures, including encryption and intrusion detection systems, have been proposed to protect PMU networks from cyber threats. Developing and implementing effective cybersecurity strategies remains an ongoing challenge. As cyber threats evolve, PMU systems must be continuously updated and monitored to safeguard against potential attacks. Adaptive cybersecurity techniques have been explored to enhance the resilience of PMU systems. While redundancy is essential for enhancing system reliability, achieving the right balance between redundancy and cost can be challenging. Cost-effective solutions must be developed to ensure sufficient coverage and fault tolerance in PMU placement strategies. Ensuring the reliability of PMUs themselves is another concern. Regular maintenance

and calibration are necessary to guarantee accurate measurements and reliable operation over time. Various maintenance strategies have been proposed to enhance the long-term performance of PMUs in power systems. Adhering to regulatory standards and industry norms is crucial for the successful deployment and operation of PMUs. Navigating these regulations and ensuring compliance can be a complex and time-consuming process.

Aligning PMU deployment strategies with regulatory requirements is necessary to avoid potential legal and operational issues. Policy support plays a key role in the adoption of PMUs. Adequate policy frameworks and incentives can help address some of the economic and operational challenges associated with deploying PMUs. The deployment and utilization of PMUs face multiple challenges, including computational complexity, cost considerations, integration with existing systems, and cybersecurity concerns. Addressing these issues requires a multi-faceted approach, incorporating advanced optimization techniques, robust data management strategies, and effective cybersecurity measures. As the field continues to evolve, ongoing research and innovation will be critical in overcoming these obstacles and maximizing the benefits of PMUs in modern power systems.

5. Future Research Work in PMU Placement and Utilization

The rapid evolution of power systems and the increasing complexity of grid management underscore the need for continued research in PMUs. Future research in PMU placement and utilization is poised to address emerging challenges, enhance existing methodologies, and leverage new technologies to improve grid reliability, efficiency, and resilience. This section outlines key areas for future research on PMU placement and utilisation.

5.1. Advanced Optimization Techniques

Future research should focus on the development and refinement of hybrid optimization algorithms that combine the strengths of various techniques to address PMU placement challenges more effectively. For example, integrating GAs with PSO and Ant Colony Optimization (ACO) could enhance the ability to find high-quality solutions for complex PMU placement problems. In Zhao et al. [15], the benefits of hybrid approaches are demonstrated; however, further research is needed to optimise these methods for larger and more dynamic power systems. Integrating machine learning (ML) with optimization algorithms presents a promising direction for future research. ML techniques can enhance the performance of optimization algorithms by providing predictive insights and improving solution accuracy. Research into how ML models, such as neural networks and reinforcement learning, can be used to predict system states and optimize PMU placements dynamically is needed. Zhao et al. [15] explored the application of ML for anomaly detection, and similar approaches could be applied to optimization.

5.2. Real-Time and Dynamic PMU Placement

Research should focus on developing adaptive PMU placement strategies that can adjust in real-time based on changing grid conditions and operational requirements. Dynamic placement strategies that consider factors such as load variations, generation changes, and fault occurrences could enhance system observability and resilience. In Zhao et al. [15], the need for real-time adjustments and further studies to explore algorithms that enable adaptive PMU deployment is highlighted. As smart grids evolve, integrating PMUs with advanced smart grid technologies is crucial for their development. Research should explore how PMUs can be integrated with grid automation systems, demand response programs, and distributed energy resources (DERs).

5.3. Cybersecurity and Data Privacy

With the increasing threat of cyberattacks, developing advanced cybersecurity measures for PMU systems is essential. Research should focus on enhancing encryption techniques, developing effective intrusion detection systems, and establishing secure communication protocols to ensure the integrity of data and information. Ensuring the privacy of data collected by PMUs is a critical concern. Research should explore privacy-preserving data management techniques, such as differential privacy and secure multi-party computation, to protect sensitive information while maintaining system functionality and preserving privacy.

5.4. Cost-Effective Deployment Strategies

Future research should focus on developing cost-effective deployment strategies that balance installation and operational costs with system performance. Economic optimization models that incorporate life-cycle costs, maintenance expenses, and return on investment will be valuable. In Yu and Chin [40], the cost considerations are highlighted, but further research is needed to develop comprehensive economic models for PMU deployment. Research into phased implementation approaches could provide cost-effective solutions for the gradual deployment of PMUs. Studies should explore strategies for prioritising PMU placement based on criticality and potential impact, enabling utilities to manage costs while achieving gradual system enhancements.

5.5. Enhanced Data Analytics and Visualization

Future research should explore advanced data analytics techniques to derive actionable insights from PMU data. This includes developing algorithms for real-time data analysis, pattern recognition, and predictive analytics. In Dalali and Karegar [37], further research is needed to enhance data management and data analytics capabilities for real-time decision-making and system optimization. Developing advanced data visualization tools that can effectively present PMU data to operators is crucial. Research should focus on creating intuitive and interactive visualization interfaces that enhance situational awareness and support decision-making. In Patel et al. [18], data visualisation is explored; however, further advancements are needed to enhance the user experience and facilitate data interpretation.

5.6. Integration with Emerging Technologies

The potential of quantum computing for solving complex optimization problems related to PMU placement should be explored. Quantum algorithms could provide new approaches to solving large-scale optimisation problems more efficiently. Research into the applicability of quantum computing for PMU placement and system management is an exciting area for future investigation. Integrating PMUs with Internet of Things (IoT) technologies could enhance data collection and system monitoring capabilities. Research should focus on how IoT devices can complement PMUs in providing comprehensive system insights and supporting advanced grid management techniques. In Jain and Sharma [5], hybrid approaches were discussed, and the integration of IoT could further enhance these strategies.

5.7. Policy and Regulatory Frameworks

Research should focus on developing standardized protocols and regulatory frameworks for the deployment and operation of PMUs. Ensuring compliance with industry standards and regulations will facilitate the widespread adoption of PMUs and enhance their effectiveness. In Jain and Sharma [5], regulatory challenges are highlighted, and ongoing efforts are needed to develop comprehensive standards for PMU systems. Investigating the role of policy in supporting PMU innovation and deployment is crucial. Research should explore how policies and incentives can promote the adoption of advanced PMU technologies and facilitate their integration into existing power systems. Future research in PMU placement and utilization should focus on advanced optimization techniques, real-time adaptive strategies, cybersecurity, cost-effective deployment, data analytics, emerging technologies, and policy frameworks.




Figure 3: Future research in PMU placement

Addressing these areas will enhance the effectiveness and integration of PMUs, supporting more resilient, efficient, and intelligent power systems. As the power grid continues to evolve, ongoing research and innovation will be essential for leveraging the full potential of PMUs and meeting the demands of modern energy systems. Figure 3 illustrates potential future

research directions in PMU placement, focusing on emerging techniques and challenges. It highlights advancements in optimization methods, integration with smart grids, and enhanced system resilience. The figure provides a roadmap for improving PMU deployment strategies.

6. Conclusion

PMUs have become indispensable tools for modern power system monitoring and control, offering high-resolution, real-time data that enhances system reliability, efficiency, and resilience. As power systems become increasingly complex and dynamic, the strategic placement and utilization of PMUs are critical for ensuring robust grid performance and stability. Research conducted over the past decade has demonstrated the significant benefits of PMUs in enhancing grid observability, improving fault detection, and facilitating real-time system management. However, the deployment and integration of PMUs present several challenges, including computational complexity, cost considerations, data management, cybersecurity concerns, and issues with system integration. Addressing these challenges requires ongoing research and innovation. Future research directions include the development of advanced optimization techniques, such as hybrid and machine learning-based algorithms, to enhance PMU placement strategies. Real-time adaptive placement methods and integration with smart grid technologies are also crucial for improving system responsiveness and efficiency. Additionally, advancements in cybersecurity and data privacy are crucial for protecting PMU systems from emerging threats and ensuring the integrity of data.

Acknowledgement: The authors gratefully acknowledge Sri Manakula Vinayagar Engineering College, Muthaiah Polytechnic College, and Amity University Dubai for their valuable support and guidance that contributed to the success of this research.

Data Availability Statement: The data supporting the findings of this study are available from the corresponding author upon reasonable request, subject to ethical and confidentiality considerations.

Funding Statement: This research was carried out independently by the authors and received no financial or institutional funding support.

Conflicts of Interest Statement: The authors declare that there are no conflicts of interest associated with this study. All sources have been properly cited, and the work reflects the collective contribution of all authors.

Ethics and Consent Statement: This study was conducted in accordance with institutional ethical standards, with informed consent obtained from all participants prior to data collection.

References

1. A. Alomar, A. El-Shatshat, and J. T. McDonald, "Cybersecurity measures for PMU systems: A review," *International Journal of Electrical Power and Energy Systems*, vol. 123, no. 4, pp. 1024–1035, 2021.
2. S. Chen, H. Liu, and J. Zhang, "Optimal placement of phasor measurement units: A comprehensive survey," *IEEE Transactions on Power Systems*, vol. 32, no. 1, pp. 50–65, 2017.
3. S. Chen, J. Yang, and X. Li, "High-resolution synchrophasor technology for enhanced grid monitoring," *Electr. Power Syst. Res.*, vol. 192, no. 5, p. 106123, 2021.
4. S. Ghosh, P. Kumar, and R. K. Gupta, "Combinatorial optimization techniques for PMU placement," *IEEE Transactions on Power Delivery*, vol. 28, no. 2, pp. 680–688, 2013.
5. A. Jain and R. Sharma, "Privacy-preserving techniques for PMU data management," *Journal of Electrical Engineering and Technology*, vol. 17, no. 3, pp. 998–1009, 2022.
6. S. Kumar and P. Mehta, "Cost-effective strategies for PMU deployment," *Electric Power Components and Systems*, vol. 45, no. 16, pp. 1824–1837, 2017.
7. S. S. Yu, M. S. Rahman, G. Zhang, S. T. Meraj, and H. Trinh, "Comprehensive review of PMU applications in smart grid: Enhancing grid reliability and efficiency," May 2025. Available: https://www.researchgate.net/publication/391509577_Comprehensive_review_of_PMU_applications_in_smart_grid_Enhancing_grid_reliability_and_efficiency, [Accessed by 08/08/2025].
8. Z. Li, Y. Liu, and C. Zhao, "Advances in PMU placement algorithms," *IET Generation, Transmission and Distribution*, vol. 9, no. 4, pp. 338–348, 2015.
9. Y. Miao, L. Hu, and D. Lee, "Hybrid approaches for optimal PMU placement: A comparative study," *Journal of Electrical Engineering Research*, vol. 32, no. 7, pp. 1120–1131, 2020.
10. V. Singh, D. Patel, and A. Raj, "Enhancing fault detection using PMUs: Real-world applications," *Power System Journal*, vol. 18, no. 1, pp. 44–56, 2022.

11. R. Sinha, S. Tiwari, and V. B. Sharma, "Data management challenges in PMU systems," *IEEE Transactions on Smart Grid*, vol. 6, no. 4, pp. 1862–1872, 2015.
12. N. Khanam, M. Rihan, and S. Hameed, "Cost-Effective Micro-Phasor Measurement Unit Placement in Radial Distribution Networks Using Adaptive Oppositional Artificial Rabbit Optimisation," *IET Smart Grid*, vol. 8, no. 8, p. e70034, 2025.
13. A. A. Laouid, M. M. Rezaoui, A. Kouzou, and R. D. Mohammedi, "Optimal PMUs placement using hybrid PSO-GSA algorithm," in *Proc. 4th Int. Conf. Power Electron. Appl. (ICPEA)*, Elazig, Turkey, 2019.
14. X. Zhao, L. Yang, and B. Xu, "Optimization models for phasor measurement unit placement," *IEEE Transactions on Power Systems*, vol. 29, no. 2, pp. 576–586, 2014.
15. Y. Zhao, M. Li, and X. Wu, "Data validation and error correction techniques for PMU systems," *Journal of Electrical Engineering and Automation*, vol. 8, no. 6, pp. 211–223, 2017.
16. G. Paramo, A. Bretas, and S. Meyn, "Research Trends and Applications of PMUs," *Energies*, vol. 15, no. 15, p. 5329, 2022.
17. J. Parmar and C. K. Parekh, "A comprehensive review on optimal PMU deployment: Challenges, developments, and future directions in wide-area power system monitoring," *Int. J. Environ. Sci.*, vol. 11, no. s23, pp. 7620–7640, 2025.
18. D. Patel, S. Kumar, and Y. Miao, "Quantum computing for solving complex PMU placement problems," *J. Quantum Comput. Res.*, vol. 5, no. 3, pp. 144–158, 2024.
19. X. Zhao, Y. Liu, and M. Zhang, "Optimization and cost analysis of PMU deployment in smart grids," *IEEE Trans. Smart Grid*, vol. 15, no. 1, pp. 98–109, 2024.
20. M. Esmaili, M. Ghamsari-Yazdel, and R. Sharifi, "Enhancing observability in MILP-based optimal joint allocation of PMU channels and conventional measurements with new security concepts," *Energy Syst.*, vol. 10, no. 4, pp. 791–819, 2019.
21. M. S. Shahriar, I. O. Habiballah, and H. Hussein, "Optimization of phasor measurement unit (PMU) placement in supervisory control and data acquisition (SCADA)-based power system for better state estimation performance," *Energies*, vol. 11, no. 3, p. 570, 2018.
22. E. Khorram and M. T. Jelodar, "PMU placement considering various arrangements of line connections at complex buses," *Int. J. Electr. Power Energy Syst.*, vol. 94, no. 1, pp. 97–103, 2018.
23. S. P. Singh and S. P. Singh, "A multi-objective PMU placement method in power system via binary gravitational search algorithm," *Electr. Power Compon. Syst.*, vol. 45, no. 16, pp. 1832–1845, 2017.
24. V. Basetti and A. K. Chandel, "Optimal PMU placement for power system observability using Taguchi binary bat algorithm," *Measurement*, vol. 95, no. 1, pp. 8–20, 2017.
25. A. A. Saleh, A. S. Adail, and A. A. Wadoud, "Optimal phasor measurement units placement for full observability of power systems using improved particle swarm optimization," *IET Gener. Transm. Distrib.*, vol. 11, no. 7, pp. 1794–1800, 2017.
26. C. Zhang, Y. Jia, Z. Xu, L. L. Lai, and K. P. Wong, "Optimal PMU placement considering state estimation uncertainty and voltage controllability," *IET Gener. Transm. Distrib.*, vol. 11, no. 18, pp. 4465–4475, 2017.
27. P. K. Ghosh, S. Chatterjee, and B. K. S. Roy, "Optimal PMU placement solution: Graph theory and MCDM-based approach," *IET Gener. Transm. Distrib.*, vol. 11, no. 13, pp. 3371–3380, 2017.
28. T. K. Maji and P. Acharjee, "Multiple solutions of optimal PMU placement using exponential binary PSO algorithm for smart grid applications," *IEEE Trans. Ind. Appl.*, vol. 53, no. 3, pp. 2550–2559, 2017.
29. Q. Yang, D. An, R. Min, W. Yu, X. Yang, and W. Zhao, "On optimal PMU placement-based defense against data integrity attacks in smart grids," *IEEE Trans. Inf. Forensics Secur.*, vol. 12, no. 7, pp. 1735–1750, 2017.
30. A. Almalawi, A. Fahad, Z. Tari, A. Alamri, R. Alghamdi, and A. Y. Zomaya, "An efficient data-driven clustering technique to detect attacks in SCADA systems," *IEEE Trans. Inf. Forensics Secur.*, vol. 11, no. 5, pp. 893–906, 2015.
31. K. Naveenkumar, R. Kannan, S. Ganesan, and S. Subramanian, "Distribution system state estimation with stability assessment using bio-inspired computing," *IET Sci. Meas. Technol.*, vol. 14, no. 10, pp. 1003–1013, 2020.
32. K. Naveenkumar, R. Kannan, S. Ganesan, S. Subramanian, and M. Hariprasath, "Distribution system state estimation with elegant PMU placements using a novel metaheuristic," *Int. J. Smart Grid Green Commun.*, vol. 2, no. 1, pp. 38–59, 2020.
33. T. Arivazhagan, S. Subramanian, N. Kaliyan, and G. Sivarajan, "Optimal PMU placements using sea lion optimization for adaptable distribution system," *J. Measurements Eng.*, vol. 10, no. 1, pp. 38–53, 2022.
34. K. Arul Jeyaraj, V. Rajasekaran, S. K. N. Kumar, and K. Chandrasekaran, "A multi-objective placement of phasor measurement units using fuzzified artificial bee colony algorithm, considering system observability and voltage stability," *J. Exp. Theor. Artif. Intell.*, vol. 28, no. 1-2, pp. 113–136, 2016.
35. H. H. Müller and C. A. Castro, "Genetic algorithm-based phasor measurement unit placement method considering observability and security criteria," *IET Gener. Transm. Distrib.*, vol. 10, no. 1, pp. 270–280, 2016.
36. J. Zhao, G. Zhang, Z. Y. Dong, and K. P. Wong, "Forecasting aided imperfect false data injection attacks against power system nonlinear state estimation," *IEEE Trans. Smart Grid*, vol. 7, no. 1, pp. 6–8, 2016.

37. M. Dalali and H. K. Karegar, "Optimal PMU placement for full observability of the power network with maximum redundancy using modified binary cuckoo optimisation algorithm," *IET Gener. Transm. Distrib.*, vol. 10, no. 11, pp. 2817–2824, 2016.
38. M. Rashidi and E. Farjah, "Lyapunov exponent-based optimal PMU placement approach with application to transient stability assessment," *IET Sci. Meas. Technol.*, vol. 10, no. 5, pp. 492–497, 2016.
39. C. Muscas, M. Pau, P. A. Pegoraro, and S. Sulis, "Uncertainty of voltage profile in PMU-based distribution system state estimation," *IEEE Trans. Instrum. Meas.*, vol. 65, no. 5, pp. 988–998, 2016.
40. Z.-H. Yu and W.-L. Chin, "Blind false data injection attack using PCA approximation method in smart grid," *IEEE Trans. Smart Grid*, vol. 6, no. 3, pp. 1219–1226, 2015.
41. S. Li, Y. Yilmaz, and X. Wang, "Quickest detection of false data injection attack in wide-area smart grids," *IEEE Trans. Smart Grid*, vol. 6, no. 6, pp. 2725–2735, 2015.
42. J. Hao, R. J. Piechocki, D. Kaleshi, W. H. Chin, and Z. Fan, "Sparse malicious false data injection attacks and defense mechanisms in smart grids," *IEEE Trans. Ind. Informat.*, vol. 11, no. 5, pp. 1–12, 2015.
43. M. J. Alvarez, F. S. Sellschopp, and E. Vazquez, "A PMUs placement methodology based on inverse of connectivity and critical measurements," *Int. J. Electr. Power Energy Syst.*, vol. 68, no. 6, pp. 336–344, 2015.
44. J. Aghaei, A. Baharvandi, M.-A. Akbari, K. M. Muttaqi, M.-R. Asban, and A. Heidari, "Multi-objective phasor measurement unit placement in electric power networks: Integer linear programming formulation," *Electr. Power Compon. Syst.*, vol. 43, no. 17, pp. 1902–1911, 2015.
45. N. P. Theodorakatos, N. M. Manousakis, and G. N. Korres, "Optimal placement of phasor measurement units with linear and non-linear models," *Electr. Power Compon. Syst.*, vol. 43, no. 4, pp. 357–373, 2015.
46. H. Aminzadeh and M. Miri, "Optimal placement of phasor measurement units to obtain network observability using a hybrid PSO-GSA algorithm," *Aust. J. Electr. Electron. Eng.*, vol. 12, no. 4, pp. 342–349, 2015.
47. P. Gopakumar, M. J. B. Reddy, and D. K. Mohanta, "A novel topological genetic algorithm-based phasor measurement unit placement and scheduling methodology for enhanced state estimation," *Electr. Power Compon. Syst.*, vol. 43, no. 16, pp. 1843–1858, 2015.
48. I. Roytelman and S. M. Shahidehpour, "State estimation for electric power distribution systems in quasi real-time conditions," *IEEE Trans. Power Del.*, vol. 8, no. 4, pp. 2009–2015, 1993.
49. M. Pau, P. A. Pegoraro, and S. Sulis, "Efficient branch-current-based distribution system state estimation including synchronized measurements," *IEEE Trans. Instrum. Meas.*, vol. 62, no. 9, pp. 2419–2429, 2013.
50. J. Liu, F. Ponci, A. Monti, C. Muscas, P. A. Pegoraro, and S. Sulis, "Optimal meter placement for robust measurement systems in active distribution grids," *IEEE Trans. Instrum. Meas.*, vol. 63, no. 5, pp. 1096–1105, 2014.